TERMS OF REFERENCE

SUPPLY AND INSTALLATION OF 7 UNITS OF ELECTROMAGNETIC FLOWMETER SENSOR (AC POWERED) COMPLETE WITH ACCESSORIES

- 1. The equipment offered shall be compatible with MCWD's existing ABB electromagnetic flowmeter transmitter;
- 2. The bidders shall submit brochure of the brand and the website link of the brochure offered for evaluation purposes of end-user; failure to submit shall automatically disqualify the bidder;
- 3. The bidders must submit certificate of after sales support which includes availability of genuine instrument spare parts for five (5) years from the date of delivery and certified service technician based in Cebu or in Metro Manila;
- 4. The bidders must show proof of experience not less than 50% of the total ABC in the supply and installation of the same or similar type of equipment subject of this bid in previously completed projects with other water districts or companies involve in water supply and distribution;
- 5. The winning bidder must certify that the unit should be brand new with manufacturing year not earlier than 2023;
- 6. The bidders must submit standard certificate of warranty against hidden factory defects covered for one (1) year;
- 7. The winning bidder shall install the equipment with proper grounding to ensure reliability of operation. MCWD will issue a certificate of satisfactory testing and completion of the equipment;
- 8. The winning bidder shall conduct seminar / training to at least (10) MCWD technical staff together with a manual in the proper operation and maintenance of equipment purchased, free of charge;
- 9. The winning bidder shall deliver the equipment/instruments with complete accessories set within 90 calendar days from the receipt of Notice to Proceed to Talamban Warehouse, Nasipit Talamban, Cebu City for inspection and possible testing.
- 10. The winning supplier shall provide in-plant product verification for three (3) MCWD personnel to ensure that the manufactured electro-magnetic flowmeter meet the required MCWD's specifications and quality standards.
- 11. The winning supplier shall submit an undertaking that all the requirements in the TOR shall be complied with accordingly.

ELECTROMAGNETIC FLOWMETER SENSOR (AC SUPPLY) COMPLETE WITH ACCESSORIES TECHNICAL SPECIFICATIONS					
Bore Size	400mm to 700mm (16in. – 28in.)				
Linear Material	Hard Rubber				
Electrode Material	Standard				
Measuring Electrodes Material	Hastelloy C-4 (2.4610)				
Grounding Accessories	2x Potential Equalizing Rings (Stainless Steel)				
Process Connection Type	ISO 7005 PN 16 EN 1092-1				
Process Connection Material	Carbon Steel				
Usage Certifications	Standard (without PED)				
Calibration Type	Standard factory calibration				
Temperature Range of	Standard design / -2060°C(-4140°F)				
Installation/Ambient Temperature Range					
Name Plate	Adhesive label				
Signal Cable Length and Type	30m (approx. 100ft) cable				
Protection Class Transmitter/ Protection	IP 67 (NEMA 4X)/ IP 68 (NEMA 6P), cable not fitted				
Class Sensor:	and not potted, sensor is IP67 with PTFE liner				
Cable Conduits	M20 x 1.5				
Power Supply Line Frequency	60 Hz				
Technical Parameters	4-20mA = 0-16000 m3/h				
B. Other Requirements					
Warranty Certification: All Sensors shall be	e guaranteed against defects in workmanship and				
materials for a period of one (1) year from	the date of acceptance.				
Certificate of Origin.					
Manufacturer and supplier must be ISO 90	01:2015 certified				
Complete Grounding Accessories (Groundi	ng Rod, Cable, Breakers, Relays and etc.) for Whole				
System					
Supplier must have a Manufacturer Author	rization Certificate specific for this project.				
- " - " - " - " - " - " - " - " - " - "					

Supplier must have Qualified Technical Support Personnel to provide after sales service. To submit

Certificate of Trainings from the Manufacturer.

ELECTROMAGNETIC FLOWMETER (SENSOR) LIST -RESERVOIR with COMPLETE ACCESSORIES

No	Reservoir Name	Flowmeter Diameter (mm)	Tag No.	Status
1 .	LAGTANG	500	LAG-01_FT001	Defective
2	TISA	700	TIS-01_FT001	Defective
		400	TIS-01-DMA_FT001	Defective
3	TALAMBAN	500	TAL-01_FT001	Defective
4	CASILI	400	CAS-01_FT001	Defective
		500	CAS-01_FT002	Defective
5	HLR LILO-AN	500	LIL-01_FT001	Defective

Prepared by:

FELIX ANTHONY P. LOPEZ

Acting Div. Manager, NRW-PAMD

Noted by:

ENRIQUE P. REYES

Acting Dept. Manager, PAMD

Approved by:

EDGAR D. ORTEGA

Acting AGM, Operations